

8.7/15KV heat shrinkable outdoor termination



-1-

TDT 3149-10

INSPECTION REPORT

| | |
|-------------------|---|
| Report number | TDT 3149-10 |
| Client | Shenzhen Woer Heat-Shrinkable Material Co., Ltd. Woer Mansion North Lanjing Road Great Industrial Area Shenzhen, Guangdong, China |
| Reference | Agreement 70048112-TDT 10-75004A |
| Concerning | Type test |
| Date | 22 June 2010 until 24 August |
| Location of tests | Inspection and Test Center of State Grid Electric Power Research Institute (SGEPRI) Wuhan, China |
| Objects | 15 kV outdoor termination for XLPE insulated cable |
| Manufacturer | Shenzhen Woer Heat-Shrinkable Material Co., Ltd. Shenzhen, Guangdong, China |

REQUIREMENTS

The requirements as mentioned in the standard IEC 60502-4 (2005).

TEST PROGRAMME

The programme was specified by the client.
For the programme reference is made to page 6 and 7.

SUMMARY AND CONCLUSION

The test results obtained relate only to the work ordered and to the material tested.
For the test programme listed in page 6 and 7, the tests were passed successfully.

Author Gu Bin

This report consists of:
39 pages incl. 12 annexes (22 pages)

KEMA Nederland B.V.

P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Arnhem, 30 September 2010

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

Utrechtseweg 310, 6812 AR Arnhem. Telephone + 31 26 3 56 22 65. Telefax + 31 26 4 46 17 26